

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	10.11.2023 / 17:00
Person / Company:	J. Robertson POS / Eni Australia
Incident:	Approx 1000 litres of diluted sludge has gone to grade.

(a) the incident causing or threatening to cause pollution	The spill was contained within the grade area where the incident occurred. However due to rain, the sludge spread further.
(b) the place where the incident occurred	Blacktip Yelcherr Gas Plant, Thammarrur. Produced Water Treatment area.
(c) the date and time of the incident	10.11.2023 / 13:00
(d) how the pollution has occurred, is occurring or may occur	Transfer hose detached from connection fitting which caused sludge to escape
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	<ul style="list-style-type: none"> • Stop the spill • Contained the spill and used spill kits where possible
(f) the identity of the person notifying the NT EPA	Mark Easterbrook – Senior Environmental Advisor.