

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	14/12/2017 8:30am (initial phone) 14/12/2017 1:30pm (Section 14 Report)
Person / Company:	AACo/NABL
Incident:	Failure of irrigation tank.

(a) the incident causing or threatening to cause pollution	Failure of irrigation tank causing high force surge of treated wastewater (ready for irrigation) and wastewater sediments to breach bunding and spill to adjacent paddock.
(b) the place where the incident occurred	AACO Livingstone Beef abattoir site – DAF area
(c) the date and time of the incident	14/12/2017 1:00am
(d) how the pollution has occurred, is occurring or may occur	Spill of treated wastewater from the irrigation tank. Sediment build-up in the tank spilled. Spill contained to grassed paddock adjacent to the Irrigation Tank. Treated wastewater and sediments did not enter any stormwater drains or riparian areas
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	Clean-up of solid materials by physical removal including scraping the surface of the contaminated area is currently underway and will be complete this afternoon. Contamination has high likelihood of being contained in the immediate area. Contamination of surface water and groundwater is highly unlikely
(f) the identity of the person notifying the NT EPA	Naomi Wilson AACo Environmental Manager