



## WATER ANALYSIS

Department of Transport & Works  
Water Division, Darwin N.T.

Laboratory Register No.

82/1735

Date received in Laboratory

27/9/82

WR 4/1A

Bottle No.  
DW73

Time of sampling

Date of sampling

## LOCATION AND DETAILS

POINT CEYLON HATCHERY WELL SN21750 DEPTH 10.5m DISCH 0.1LPS

WRD 6002

80/2096

RSP901

Proposed water use:- Domestic, Stock, Irrigation, other (specify)

## ANALYSIS - PHYSICAL

<input checked="" type="checkbox"/> pH	3.0	<input type="checkbox"/> Colour (Hazen units)
<input type="checkbox"/> Specific conductance (microsiemens/cm at 25° C)	17400	<input type="checkbox"/> Turbidity (NTU's)
<input type="checkbox"/> Total dissolved solids (mg/l - by evaporation at 180° C)		<input type="checkbox"/> Suspended solids (mg/l)

## ANALYSIS - CHEMICAL (mg/l)

<input type="checkbox"/> Sodium, Na	<input type="checkbox"/> Chloride, Cl	61.30
<input type="checkbox"/> Potassium, K	<input type="checkbox"/> Sulphate, SO <sub>4</sub>	
<input type="checkbox"/> Calcium, Ca	<input type="checkbox"/> Nitrate, NO <sub>3</sub>	
<input type="checkbox"/> Magnesium, Mg	<input type="checkbox"/> Bicarbonate, HCO <sub>3</sub>	
<input type="checkbox"/> Total Hardness (as CaCO <sub>3</sub> )	<input type="checkbox"/> Carbonate, CO <sub>3</sub>	
<input type="checkbox"/> Total Alkalinity (as CaCO <sub>3</sub> )	<input type="checkbox"/> Fluoride, F	3030
<input type="checkbox"/> Iron, (total) Fe	<input type="checkbox"/> Orthophosphate, PO <sub>4</sub>	
<input type="checkbox"/> Silica, SiO <sub>2</sub>	<input type="checkbox"/> NaCl (calc. from chloride)	10100

## ANALYSIS - ADDITIONAL (mg/l)

<input type="checkbox"/> Copper, Cu	<input type="checkbox"/> Lead, Pb	<input type="checkbox"/> Arsenic, As
<input type="checkbox"/> Manganese, Mn	<input type="checkbox"/> Zinc, Zn	<input type="checkbox"/> Cadmium, Cd
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

SAMPLE CHANGED TO LIMITED ANALYSIS AS SPECIFIC CONDUCTANCE IS TOO HIGH

The sample as analysed is considered suitable for:-

Drinking water -

Yes/No

Stock watering -

Yes/No

Irrigation -

Yes/No

Others (specify)

Yes/No



This Laboratory is registered by the National Association of Testing Authorities, Australia. The work reported herein has been performed in accordance with the terms of registration. This document shall not be reproduced except in full.

Analysed By: G. JOHNSTON

Date 1/1 / 10 82

Boxes marked thus ☒ indicate levels considered undesirable for drinking water by the Northern Territory Department of Health.

## FINAL STATEMENT OF BORE

1.N. 80/2036

R.N. 21750

From	To	Description of Strata	Name of Bore —
<p>LATERAL FC Clay - White, Pink.</p> <hr/> <p>Location of Bore (or supply sketch on the back hereof) —            .....Miles      150 M Due South of Point Caylor Coastline</p> <p>(a) S SE of (b).....                  E NW                  W SW</p> <p>(a) Circle appropriate direction.            (b) Use known point such as existing bore, homestead, outstation, etc.            6 R 688 950 on 1:100 000 Bynoe</p> <p>Additional information of interest about bore.      ZONE 52            Grid Reference 668800 - 3595000      38 85.            Map Number Bynoe 1:100 000 Sheet 5072            Samples of Strata and Water Supplies                  have been*      will be*            left at the following place —</p> <p>Signature _____</p> <p>*Delete non applicable            INFO SUPPLIED BY R. JETNER</p> <p>For Office use only —            Plotted 24/9/82 [initials]</p>			Hatchery Well
			Name of Property — FINNIS RIVER P.L.
			Description of Property — PASTORAL LEASE
			Name of Owner — TERRA CO PTY LTD
			Name of Contractor — BLACKMORE DRILLERS
			Name of Driller — _____
Date of Commencement — July '82			
Date of Completion — _____			
Total Depth — 10.5 M (Now 8.5 M)			
Particulars of Casing — 6 M x 1 1/2 inch galvanized corrugated pipe	900 MM		
Particulars of Perforations or Screens — _____			
Water	1st Supply	2nd Supply	3rd Supply
Struck at 3 M			
Standing Water Level 3 M			
Pumping Supply Litres/sec	(0.06 — 0.18 L/s) 50 — 120 gph		
Duration of Pump Test _____			
Water Level During Test _____			
Quality: Good, Fair or Bad			

## WATER ANALYSIS

 Department of Transport & Works  
 Water Division, Darwin N.T.


80/2485

Laboratory Register No EA-ES 10889

Date received in Laboratory 24-10-85

Time of sampling 1045

Date of sampling 23-10-85

WR 4/1A

Bottle No. JA36

LOCATION AND DETAILS POINT CAYLON PH 23.76 DEPTH 25M DISCH 0.64 LPS

COND 260 WRD 6002

RSP 901

Proposed water use: Domestic, Stock, Irrigation, other (specify)

## ANALYSIS - PHYSICAL

<input type="checkbox"/> pH	7.1	<input type="checkbox"/> Colour (Hazen units)
<input type="checkbox"/> Specific conductance (microsiemens/cm at 25° C)	270	<input type="checkbox"/> Turbidity (NTU's)
<input type="checkbox"/> Total dissolved solids (mg/L - by evaporation at 180° C)	190	<input type="checkbox"/> Suspended solids (mg/L)

## ANALYSIS - CHEMICAL (mg/L)

<input type="checkbox"/> Sodium, Na	12	<input type="checkbox"/> Chloride, Cl	8
<input type="checkbox"/> Potassium, K	2	<input type="checkbox"/> Sulphate, SO <sub>4</sub>	6
<input type="checkbox"/> Calcium, Ca	9	<input type="checkbox"/> Nitrate, NO <sub>3</sub>	<1
<input type="checkbox"/> Magnesium, Mg	21	<input type="checkbox"/> Bicarbonate, HCO <sub>3</sub>	156
<input type="checkbox"/> Total Hardness (as CaCO <sub>3</sub> )	109	<input type="checkbox"/> Carbonate, CO <sub>3</sub>	
<input type="checkbox"/> Total Alkalinity (as CaCO <sub>3</sub> )	128	<input type="checkbox"/> Fluoride, F	0.3
<input type="checkbox"/> Iron, (total) Fe	0.4	<input type="checkbox"/> Orthophosphate, PO <sub>4</sub>	
<input type="checkbox"/> Silica, SiO <sub>2</sub>	70	<input type="checkbox"/> NaCl (calc. from chloride)	12

## ANALYSIS - ADDITIONAL (mg/L)

<input type="checkbox"/> Copper, Cu	<input type="checkbox"/> Lead, Pb	<input type="checkbox"/> Arsenic, As
<input type="checkbox"/> Manganese, Mn	<input type="checkbox"/> Zinc, Zn	<input type="checkbox"/> Cadmium, Cd
<input type="checkbox"/> Nickel, N	<input type="checkbox"/> Cobalt, Co	<input type="checkbox"/>

THE SAMPLE AS ANALYSED COMPLIES/DOES NOT COMPLY WITH NORTHERN TERRITORY DRINKING WATER STANDARDS AS RECOMMENDED BY THE NORTHERN TERRITORY DEPARTMENT OF HEALTH.



This Laboratory is registered by the National Association of Testing Authorities, Australia. The tests reported herein have been performed in accordance with its terms of registration. This document shall not be reproduced except in full.

Analysed By: [Signature] Date 1/11/85

Boxes marked thus ☒ indicate results considered undesirable for drinking water by the Northern Territory Department of Health.

## FINAL STATEMENT OF BORE



I.N. 80/2485

R.N. 23,176

From	To	Description of Strata (including colour and hardness)	Name of Bore —																												
0.0-7.0		greenish brown clay	FF 478																												
7.0-11.5		As above, damp	Name of Property —																												
11.5-15.0		Moderately fresh, calcareous chloritic and biotitic rock. Fresh pyrite.	BYNOE																												
15.0-36.0		As above, with brecciated quartz. Lies on Pt. Gaylor Fault.	Description of Property —																												
*standing: Hermit GK Metamorphics - west Litchfield complex.			E.L. 1753																												
Location of Bore (or supply sketch on the back hereof) —			Name of Owner —																												
..... km			AUSTRALIAN COAL & GOLD HOLDINGS LTD.																												
(a) S SE of (b) AC GOLD GRID 62N 9W SW E-NW W-SW			Name of Contractor —																												
(a) Circle appropriate direction. (b) Use known point such as existing bore, homestead, outstation, etc.			AS ABOVE																												
Additional information of interest about bore. 66.1750 - 85.91900 Grid Reference (92-68) 67-999 Map Number BYNOE 5072 1:100,000			Name of Driller —																												
Samples of Strata and Water Supplies have been* will be*			E. LETZIGT																												
left at the following place — STRATA ON SITE, WATER SAMPLE AT WATER RESOURCES David Porter Signature			Date of Commencement —																												
*Delete non applicable			17. 11. 83																												
For Office use only — Plotted 23/8/84			Date of Completion —																												
			17. 11. 83																												
			Total Depth —																												
			36 m																												
			Particulars of Casing —																												
			CASED TO 18.0m - 125mm PVC																												
			Particulars of Perforations or Screens —																												
			SLOTTED 16-18 m																												
			<table border="1"> <tr> <th>Water</th> <th>1st Supply only</th> <th>2nd Supply only</th> <th>3rd Supply only</th> </tr> <tr> <td>Struck at</td> <td>11.5</td> <td>15.0</td> <td>25.0</td> </tr> <tr> <td>Standing Water Level</td> <td>11.5</td> <td></td> <td></td> </tr> <tr> <td>Pumping Supply Litres/sec.</td> <td>NIL</td> <td>(0.25-0.5) 200-500</td> <td>(2.54/s) 2000</td> </tr> <tr> <td>Duration of Pump Test</td> <td></td> <td>AIRLIFTED 15 min</td> <td>AIRLIFTED 2 hr.</td> </tr> <tr> <td>Water Level During Test</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Quality: Good, Fair or Bad</td> <td>GOOD</td> <td>GOOD</td> <td>GOOD</td> </tr> </table>	Water	1st Supply only	2nd Supply only	3rd Supply only	Struck at	11.5	15.0	25.0	Standing Water Level	11.5			Pumping Supply Litres/sec.	NIL	(0.25-0.5) 200-500	(2.54/s) 2000	Duration of Pump Test		AIRLIFTED 15 min	AIRLIFTED 2 hr.	Water Level During Test				Quality: Good, Fair or Bad	GOOD	GOOD	GOOD
Water	1st Supply only	2nd Supply only	3rd Supply only																												
Struck at	11.5	15.0	25.0																												
Standing Water Level	11.5																														
Pumping Supply Litres/sec.	NIL	(0.25-0.5) 200-500	(2.54/s) 2000																												
Duration of Pump Test		AIRLIFTED 15 min	AIRLIFTED 2 hr.																												
Water Level During Test																															
Quality: Good, Fair or Bad	GOOD	GOOD	GOOD																												

File  
RN 23176  
22/10/85

POINT CEYLON

22/10/85

TEST PUMPING

Introduction

On the 22/10/85 a pump test crew visited Point Ceylon to test RN 23176.

Work Done

On the 22/10/85 a mono 620 pump was set at 18.80 m and a preliminary test started at 0.64 L/s, discharge was clear and conductivity 260.

The bore forked at 23 minutes into the test. Pumping 0.4 L/s to 0.5 L/s on the fork, still clear discharge. On 23/10/85 the mono 620 was lowered to 25 m and a test started at 0.64 L/s the lowest we could pump. The discharge was clear, conductivity 240, the bore forked pumping 0.4 L/s to 0.5 L/s on fork. After 47 minutes, recovery was taken and bore recovered to 2.95 m to S.W.L. in 90 minutes.

Comments

Total depth of bore before testing was 32.50 m after testing the total depth was 28.35 m. When running the pump it was noted that the column was dragging the sides of the bore, this may indicate the bore is not straight. Also it was very difficult to get reading as the mega line kept jamming as the bore drew down, this bore is only cased with 125 mm PVC to 18 m.

ANTHONY PARKER

*Anthony Parker*