

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	20/03/17 1600hrs
Person / Company:	Wayne Burton Plantation Management Partners for Tiwi Plantation Corporation
Incident:	Tannin water mixed with storm water release
(a) the incident causing or threatening to cause pollution	It has been reported on the 17 th March 2017 a discharge event occurred at Port Melville Basin 1 and 4. The discharge was not noticed by Tiwi Plantation staff but reported to Wayne Burton and Roger Smith via email from Chris Litowchak, Chief Operating Officer, Teras Australia (Port Melville) at 12.50 pm on the 20 th March.
(b) the place where the incident occurred	Port Melville Tiwi Island
(c) the date and time of the incident	17 th March 2017
(d) how the pollution has occurred, is occurring or may occur	Tannin from woodchip stockpiles is leaching into port drainage system along with storm water. Rainfall event caused basins to fill and overflow.
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	Pumping system failed during this event. Installation of larger capacity pumps that are automated are planned. Sampling of the event was not possible by Tiwi Plantation Corporation, due to being unaware of the event.
(f) the identity of the person notifying the NT EPA	Wayne Burton 0474263006