

**SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)**

<b>Date and Time of Notification:</b>	14 <sup>th</sup> April 2022 at 8:40 am Pollution Hotline Notified at 4:32 pm
<b>Person / Company:</b>	Mick Atkin, Veolia
<b>Incident:</b>	Leachate spill.

<b>(a) the incident causing or threatening to cause pollution</b>	A leachate transfer pipe fitting failure.
<b>(b) the place where the incident occurred</b>	On the eastern side of the access road between stage 3 and stage 2 along the internal fence line.
<b>(c) the date and time of the incident</b>	14 <sup>th</sup> of April 2022 exact time not known.
<b>(d) how the pollution has occurred, is occurring or may occur</b>	A valve used to connect two lengths of poly pipe has failed causing the two sections of pipe to separate.
<b>(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident</b>	The feed pumps were turned off immediately from stage 3, the onsite vac truck was used to clean up the leachate that went to ground. Soil bunds were placed preventing the possibility of leachate entering the stormwater drains. Contaminated soil was removed from areas impacted by leachate.
<b>(f) the identity of the person notifying the NT EPA</b>	Shane Coleman City of Darwin