

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	26 December 2017 at approx. 21:53pm (CST)
Person / Company:	Power and Water Corporation (PWC)
Incident:	Discharge of raw sewage from sewerage network (rising main)

(a) the incident causing or threatening to cause pollution	Discharge of raw sewage to land from sewerage network (rising main) associated with equipment failure.
(b) the place where the incident occurred	213 Dickward Drive Coconut Grove LONG: 130°51. 5.040E LAT: 12°24 48.6S
(c) the date and time of the incident	At this stage, the exact date, time and potential duration of the incident is unclear to PWC. PWC notified by member of public on 26 December 2017 at approx. 1600 hours
(d) how the pollution has occurred, is occurring or may occur	Pipe seal failure/crack.
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	Clean up undertaken in accordance with standard operating procedure including: installation of temporary barriers/warning signs, management notified, containment of spill to defined area via natural land depression and application of disinfectant. Repairs made to rising main and site remediated via removal of contaminated material and reinstatement of clean fill.
(f) the identity of the person notifying the NT EPA	PWC Environmental Team on behalf of Water Services