

Attachment 4 - Groundwater Monitoring Program

Parameter	Units	Frequency (all monitoring bores identified in Attachment 5)
Field Measurement		
Flow	kL/day	M ¹
Standing Water Level (SWL)	m AHD	M
pH	pH units	Q
Electrical Conductivity (EC)	µS/cm	Q
Dissolved Oxygen (DO)	% saturation	Q
Temperature	°C	Q
Reduction Oxidation Potential (REDOX)	mV	Q
Metals/Metalloids (filtered (0.45µm))		
Arsenic (As)	µg/L	A
Boron (B)		Q
Cadmium (Cd)		A
Chromium (Cr)		Q
Cobalt (Co)		A
Copper (Cu)		Q
Lead (Pb)		Q
Lithium (Li)		A
Nickel (Ni)		Q
Vanadium (V)		A
Zinc (Zn)		Q
Major Ions		
Carbonate (CO ₃)	mg/L	Q
Bicarbonate (HCO ₃)		Q
Calcium (Ca)		Q
Magnesium (Mg)		Q
Potassium (K)		Q
Sodium (Na)		Q
Chloride (Cl)		Q
Sulphate (SO ₄)		Q
Nutrients		
Ammonia (NH ₃ as N)	µg/L	Q
Ammonium (NH ₄)		Q
Nitrate (NO ₃)		Q
Nitrite (NO ₂)		Q
Oxides of Nitrogen (NO _x)		Q
Total Nitrogen (TN)		Q
Total Phosphorous (TP)		Q
Hydrocarbons		
Total Recoverable Hydrocarbons (TRH)	µg/L	A
Benzene		A
Toluene		A
Ethylbenzene		A
Xylene		A
Naphthalene		A
PFAS (per-and poly-fluoroalkyl substances) (Analysis on a minimum of 28 PFAS compounds using LC-MS/MS)		
PFOS	µg/L	Q
PFOA		Q

Parameter	Units	Frequency (all monitoring bores identified in Attachment 5)
Other		
Chemical Oxygen Demand (COD)	mg/L	Q
Total Organic Carbon (TOC)		Q
Total Dissolved Solids (TDS)		Q
Organophosphate Pesticides	µg/L	A
Organochlorine Pesticides		A
Polychlorinated Biphenyls		A
Tributyltin Oxide		A
Phenols		A
Escherichia Coli	CFU 100mL	A
Enterococci		A
M – Monthly Q – Quarterly (January, April, July, October) A – Annually (January) ¹ – If the water level is above top of casing when measuring SWLs then estimate the flow.		