

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	12 th November 2024 Time 13:15hrs
Person / Company:	Mr Peter Levett Regional Manager South Territory Generation E: Peter.Levett@territorygeneration.com.au
Incident:	Diesel spill from CAT Generators

(a) the incident causing or threatening to cause pollution	At around 3:00pm on Friday 8 th November 2024 there was a diesel spill of approximately 200L outside of the generator bund. No diesel migrated from the station, nor did it enter any stormwater drainage systems. The spill has been contained to a localised area near the CAT Generators.
(b) the place where the incident occurred	Yulara Power Station Map coordinate -25.232479, 130,991664 Cat Generators Unit 20 and 21
(c) the date and time of the incident	The spill occurred at approximately 3:00pm on Friday 8 th November 2024.
(d) how the pollution has occurred, is occurring or may occur	Potential fault with actuated fuel valves (pending further investigation) resulting in the overfilling of generator day tanks.
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	Immediate actions taken following the spill included: <ul style="list-style-type: none"> - Fuel was manually isolated. - Site team mobilised, commenced use of spill kits to contain leaked fuels and conduct initial clean-up. - TGen sourcing a contractor in the area to remediate site.
(f) the identity of the person notifying the NT EPA	Mrs Andrea Kittel HSE Manager Territory Generation E: Andrea.Kittel@territorygeneration.com.au