

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	09/02/2026 @12:30pm (ACST)
Person / Company:	Kurt Kavanagh, Consultex on Behalf of Total Piping & Mechanical
Incident:	Diesel Spill from Generator at Port of Darwin
(a) the incident causing or threatening to cause pollution	Diesel Spill from Generator near Port/Open water
(b) the place where the incident occurred	Port of Darwin 880 Berrimah Road, East Arm NT 0822
(c) the date and time of the incident	09/02/2026 @06:30am (ACST)
(d) how the pollution has occurred, is occurring or may occur	Failure of a line/hosing on the generator, resulting in an uncontrolled release of liquid.
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	At time of incident, diesel was contained with absorbent pads and sand. An exclusion zone was erected to contain site during preservation. Power to the generator was cut immediately and the hire company (owners for generator) attended site to repair the split hose. After initial notification to regulator, the site was cleaned as per clearance from NT Regulator.
(f) the identity of the person notifying the NT EPA	Kurt Kavanagh, Consultex on Behalf of Total Piping & Mechanical



IMG_20260209_071756.jpg



IMG20260209064209.jpg



IMG20260209064214.jpg



IMG20260209064218.jpg



IMG20260209075747.jpg



IMG20260209075756.jpg



Damage to Line 1



Initial Spill 1



Initial Spill 2



Initial Spill 3



Contained Spill 1



Contained Spill 2



Cleaning In Progress 1



Cleaning In Progress 2



Cleaning In Progress 3