

**Summary of Notification of Incident
- pursuant to Section 14 of the
Waste Management and Pollution Control Act**

7/12/2011

**Company: Power Water Corporation
Incident: Pine Creek Sub Station Transformer Oil
Location: Pine Creek**

THE IDENTITY OF THE PERSON NOTIFYING OF THE INCIDENT –

Cathy Waldron

THE INCIDENT CAUSING OR THREATENING TO CAUSE POLLUTION –

Leaking oil from 2 transformers at the Pine Creek 66KV Zone Sub Station.

THE PLACE WHERE THE INCIDENT OCCURRED –

Pine Creek Sub Station.

THE DATE AND TIME OF THE INCIDENT –

Unknown

HOW THE POLLUTION OCCURRED, IS OCCURRING OR MAY OCCUR –

The transformers are banded and it was believed the bands were connected to an oil water separator, however investigations have not located such a unit and the band may empty into an absorption trench. An investigation is continuing.

THE ATTEMPTS MADE TO PREVENT, REDUCE, CONTROL, RECTIFY OR CLEAN UP THE POLLUTION OR RESULTANT ENVIRONMENTAL HARM CAUSED OR THREATENING TO BE CAUSED BY THE INCIDENT –

A consultant is being engaged to determine the level and extent of any soil/water contamination. PWC is also in the process of arranging for an oil water separator to be installed. There is a process in place to replace/repair the transformers.