

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	Monday 8 th March 2021, 14:00.
Person / Company:	Erica Eastick, Ventia
Incident:	Sewer pump station overflow discharging to stormwater drain and moving off-site

(a) the incident causing or threatening to cause pollution	System failure causing discharge of overflow
(b) the place where the incident occurred	Robertson Barracks, Palmerston. (see page 2 for location map)
(c) the date and time of the incident	Monday 8 th March 2021; incident likely to have occurred overnight and detected in the morning.
(d) how the pollution has occurred, is occurring or may occur	Likely system failure (being investigated internally).
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	Pump station holding tank pumped out to avoid further overflow; drain sandbagged near boundary to minimise movement off site; contaminated liquid on site and over-the-fence removed by licenced sucker-truck and disposed of at licenced premise.
(f) the identity of the person notifying the NT EPA	Erica Eastick



ROBERTSON BARRACKS

Pump station

Location of incident



Drain

Boundary