

Submission on Supplementary Environment Report (SER)

Santos – Darwin Pipeline Duplication

Government authority: Power and Water Corporation

Summary: Power and Water's undersea power cables are oil-filled so there is the potential for oil discharge into the harbour in the event of cable damage. Hence our request that Power and Water Corporation be consulted with respect to the detailed design and proposed protection measures of Santos's crossing of the Darwin to Mandorah undersea oil-filled power cables.

Section of Referral	Theme or issue	Comment
Page 48	Possible oil spill in a marine environment	<ul style="list-style-type: none"> In section 2.3.6 (cable crossing) SER states that a 'detailed survey will be undertaken prior to any activities performed in the vicinity of the power and telecommunication routes.' When this occurs please include Power and Water in consultations