

**SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)**

<b>Date and Time of Notification:</b>	26/09/17 16:45pm
<b>Person / Company:</b>	Power and Water Corporation
<b>Incident:</b>	Overflow of sewage from manhole
<b>(a) the incident causing or threatening to cause pollution</b>	Discharge of sewage to land and storm water drain associated with blocked sewer main. Blockage caused by trees roots, grease and paper towel.
<b>(b) the place where the incident occurred</b>	32 Lorna Lim Terrace
<b>(c) the date and time of the incident</b>	Total time unknown, PWC notified by member of the public 26/9/17 at 1400 and blockage was cleared by 1500
<b>(d) how the pollution has occurred, is occurring or may occur</b>	Raw sewage overflow.
<b>(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident</b>	Clean up consistent with overflow response procedure (ie: Area has been barricaded off, solids/material removed, vacuum truck used to remove any liquid pooling on ground and within stormwater drain). CCTV investigation will be undertaken to check condition of asset.
<b>(f) the identity of the person notifying the NT EPA</b>	PWC Environmental Services Team on behalf of Water Services