

## SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

<b>Date and Time of Notification:</b>	Tuesday the 17 <sup>th</sup> of May 2022, NT EPA notified (Kiara Ware) at 12:48pm, NT EPA Hotline notified at 12.59pm
<b>Person / Company:</b>	Mick Atkin Veolia
<b>Incident:</b>	Both leachate holding ponds are over topping at spillway.

<b>(a) the incident causing or threatening to cause pollution</b>	Leachate is escaping the leachate ponds and is being contained at the GWILP to the east of the two leachate ponds.
<b>(b) the place where the incident occurred</b>	Northern end of Shoal Bay landfill at the leachate holding ponds.
<b>(c) the date and time of the incident</b>	Tuesday the 17 <sup>th</sup> of May 2022 at 10:45 am
<b>(d) how the pollution has occurred, is occurring or may occur</b>	Both ponds have exceeded holding capacity.
<b>(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident</b>	The leachate is being contained at the ground water interception point (GWILP) and is being managed by a vac truck which is recirculating the leachate via the intermediate tanks and leachate ponds. Leachate is being irrigated on top of the southern bench of stage 3, stage 6B will be added tomorrow to the irrigation program. Both BeneVap machines are operating at full capacity evaporating leachate. Cleanaway have been requested to increase their removal of leachate off site. Additional 13ML storage tank is due for completion on Friday the 27 <sup>th</sup> of May.
<b>(f) the identity of the person notifying the NT EPA</b>	Shane Coleman City of Darwin