

2025 Environmental Risk Assessment – Ramingining Wastewater Treatment Plant WDL 206-04

January 2025

Document Details and History

Document Title:	2025 Environmental Risk Assessment - Ramingining Wastewater Treatment Plant WDL 206-04		
TRIM Container:	F2016/721	Document #	D2025/38026
Version:	Date Prepared:	Prepared by:	Version reviewed by/Issued to:
Draft 0.1	06/09/2016	Sarah Gilley Power and Water Corporation	Nadine Riethmuller & David Sweeney Power and Water Corporation
Final 1.0	03/02/2017	Remote Water Planning	Department of Environment and Natural Resources Northern Territory Government waste@nt.gov.au
Draft 0.2	13/04/2020	Emma Fakes Power and Water Corporation	Simon Ruckenstein Jessica Huxley Power and Water Corporation
Final 2.0	24/04/2020	Remote Water Planning	Department of Environment, Parks and Water Security Northern Territory Government waste@nt.gov.au
Draft 0.3	26/04/2022	Emma Fakes Power and Water Corporation	Tahlia Kemp Power and Water Corporation
Final 3.0	18/07/2022	Water Services Remote	Department of Environment, Parks and Water Security Northern Territory Government waste@nt.gov.au
Draft 0.4	19/11/2024	Ashley Beagley Power and Water	Tahlia Kemp Power and Water
Final 4.0	31/01/2025	Natasha McBride Power and Water	Department of Lands, Planning and Environment (DLPE) waste@nt.gov.au
Date of Submission:	31 January 2025		

Abbreviations and Glossary

Abbreviation	Definition
ANZECC	Australian Water Quality Guidelines for Fresh and Marine Waters
ARMCANZ	Agriculture and Resources Management Council of Australia and New Zealand
Assessment endpoints	The explicit expressions of the actual environmental value that is to be protected, operationally defined by an ecological entity and its attributes.
BOD	Biochemical oxygen demand
BUD	Beneficial Use Declaration – the uses of water specified in subsection 3 of the <i>Water Act</i> (1992)
BOM	Bureau of Meteorology
CSM	Conceptual site model
Cultural values	To provide water to meet aesthetic, recreational and cultural needs.
DLPE	Department of Lands, Planning and Environment (NT)
DO	Dissolved oxygen
<i>E. coli</i>	<i>Escherichia coli</i>
Ebb tide	A falling tide - the phase of the tide between high water and the succeeding low water.
Environmental Values	To provide water to maintain the health of aquatic ecosystems.
EPBC	Environment Protection and Biodiversity Conservation Act
ERA	Environmental risk assessment
ET	Equivalent Tenement – an average residential dwelling or house. Other developments are converted to an ET value by relating their average water demand (or sewage flow) to demand from one average house.
Flood tide	A rising tide - the phase of the tide between low water and the next high tide.
ICEGs	Indigenous Community Engineering Guidelines
kL	Kilolitre
Km	Kilometre
L	Litre
m	Metre
m ²	Square metre
Macrotidal estuary	Estuaries where the tidal range is in excess of 4 metres.
mg	Milligram
mL	Millilitre
NO _x	Nitrogen oxides – the sum of nitrate and nitrite ionic species.
NT	Northern Territory

NTU	Nephelometric turbidity units
NT EPA	Northern Territory Environmental Protection Authority
PL	Primary lagoon
Risk characterisation	The culmination of the planning, problem formulation and analysis of predicted or observed adverse ecological effects related to the assessment endpoints.
Risk hypothesis	Assumptions made in order to evaluate logical or empirical consequences, or suppositions tentatively accepted to provide a basis for evaluation. They are used to test if an activity (e.g. contaminant discharges) has adverse effects on an assessment endpoint.
SL	Secondary lagoon
SOCs	Site of conservation significance
SPS(s)	Sewage pump station(s)
SS / TSS	Suspended solids / total suspended solids
TDS	Total dissolved solids – the portion of solids in wastewater that passes through a 2.0 micron filter.
TN	Total nitrogen
TP	Total phosphorous
TPWC	Territory Parks and Wildlife Conservation Act
WDL	Waste discharge licence
WwTP	Wastewater treatment plant. All facilities that treat wastewater disposed of to the sewerage system consisting primarily of sewage as well as stormwater inflow and infiltration. These facilities may include a range of different types of treatment technologies e.g. waste stabilisation ponds.
WSP(s)	Waste stabilisation pond(s)

Executive Summary

This desktop environmental risk assessment (ERA) provides an assessment of the risks associated with the discharge of secondary treated effluent from the Ramingining wastewater treatment plant (WwTP) to the Arafura Swamp (Glyde River) via an unnamed surface watercourse.

Based on this ERA and water quality data, there is limited evidence to suggest deleterious impacts on the environmental values identified for this receiving environment. Risks to the assessment end-points, associated with the source, were assessed as having medium to high risk rankings. These rankings were associated with the low discharge volumes into a freshwater environment, while higher risk rankings were associated with impacts to cultural values including human health risks through primary and secondary contact and aquatic food safety.

The risk rankings may change as uncertainties associated with current assessments are addressed. A range of recommendations have been made in this risk assessment to address knowledge gaps and identify opportunities for improvement.

Contents

List of Figures	Error! Bookmark not defined.
List of Tables	Error! Bookmark not defined.
1. Introduction	8
1.1 Background	9
2. Risk Assessment Methodology	9
2.1 Limitations	10
3. Problem Formulation	10
3.1 Ramingining Wastewater Treatment Plant	10
3.2 Discharge Regime	11
3.3 Pond Performance	12
3.4 Receiving Environment	13
3.5 Screening Level Risk Assessment	14
4. Risk Analysis and characterisation	17
4.1 Power and Water Risk Management Framework	17
3.1.1 Risk assessment for key indicators and stressors identified in screening level assessment.	18
5. Summary	19
References	20
Appendix 1 – Ramingining Conceptual Site Model	22
Appendix 2 – Map of Arafura Swamp Site of Conservation Significance	0
Appendix 3 – Power and Water Risk Matrix	0
Appendix 4 – Water quality and estimated dilution Ratio for Ramingining WwTP and Arafura Swamp	0

List of Figures

<u>Figure 1: Ramingining location (Google Earth, 2016)</u>	8
<u>Figure 2: Ramingining site layout including WwTP and Outfall (NT ILIS 2016)</u>	9
<u>Figure 3: Risk Assessment framework for wastewater discharges to waterways (Victoria EPA, 2023)</u>	10
<u>Figure 4: Ramingining wastewater collection and treatment configuration.</u>	11
<u>Figure 5: Unnamed Creek (2011)</u>	13
<u>Figure 6: Ramingining discharge point (2022)</u>	13
<u>Figure 7: Conceptual site model for the Ramingining WwTP</u>	22
<u>Figure 8: Ramingining coastal site of significance map (NRETAS, 2008)</u>	25
<u>Figure 9: Power and Water likelihood, risk ranking, actions and reporting matrix.</u>	27
<u>Figure 10: Approximate catchment surrounding unnamed surface watercourse downstream of Yirrkala WwTP outfall (Google Earth, 2017)</u>	28

List of Tables

<u>Table 1: Conservation status of species at risk from the Ramininging WwTP.</u>	14
<u>Table 2: Identified values of receiving environment at risk from the Ramininging WwTP.</u>	15
<u>Table 3: Screening level risk assessment for key indicators and stressors associated with Ramininging WwTP discharge.</u>	16
<u>Table 4: Risk assessment for key environmental and cultural assessment endpoints associated with Ramininging WwTP discharge.</u>	18
<u>Table 5: Power and Water risk consequence table.</u>	26
<u>Table 6: Discharge volume and dilution ratio estimate</u>	28
<u>Table 7: Summary of 2023-2024 Ramininging water quality results</u>	28

1.Introduction

Power and Water operate the Ramingining WwTP pursuant to Waste Discharge Licence (WDL) 206-4 issued on 11 July 2023. This WDL allows for continuous discharge of secondary treated sewage effluent from an authorised discharge point to the Arafura Swamp (Glyde River) via an unnamed surface watercourse.

Ramingining is located approximately 580 km east of Darwin on the edge of the heritage listed Arafura Wetlands in Central Arnhem Land (Figure 1). Ramingining has an estimated population of 956 (BushTel 2024). The Wastewater Treatment Plant (WwTP) is located approximately 744 m northeast of the Ramingining Township (Figure 2).




Figure 1: Ramingining location (Google Earth, 2016)



Figure 2: Ramingining site layout including WwTP and outfall location (NT ILIS 2016)

1.1 Background

Condition 43 (Item 15) of this WDL requires Power and Water to submit to the Northern Territory Environment Protection Authority (NT EPA) an updated ERA for the Licenced Activity by 1 February 2025.

The ERA must:

- i. be conducted with reference to a conceptual site model;*
- ii. characterise the impacts of discharge(s) on the relevant environmental values; and*
- iii. inform the development of a Performance Improvement Plan.*

2. Risk Assessment Methodology

The purpose of the desktop ERA is to:

- identify assessment endpoints;
- characterise environmental risks associated with the facility; and
- initiate an ongoing iterative environmental risk process associated with ongoing operation of the facility.

The methodology employed has been adapted from ERAs completed by the Power and Water's Assurance Team and the Victorian EPA *Guidance for Environmental and Human Health Risk Assessment of Wastewater Discharges to Surface Waters* (VIC EPA 2023). The guidelines utilise a framework (Figure 3) consistent with current nationally and internationally accepted risk assessment approaches.




Figure 3: Risk Assessment framework for wastewater discharges to waterways (Victoria EPA, 2023)

2.1 Limitations

The following items have been identified as limitations associated with the preparation of this ERA:

- limited availability of inflow/outflow data;
- remoteness of communities impacting on the ability to understand systems due to costs, logistics and available expertise; and
- limited access to pond discharge points and surrounding environment due to climatic, safety and geographic factors.

3. Problem Formulation

The purpose of this ERA is to characterise the impacts of discharge on the relevant values and has been prepared with reference to section 1.1.

This problem is explored through the following:

- characterisation of the treated effluent discharged to the receiving environment;
- characterisation of the treated effluent discharge regime and subsequent dilution of treated effluent within receiving water; and
- identified values of receiving water and assessment endpoints representative of those values.

3.1 Ramining Wastewater Treatment Plant

The community utilises a gravity and pressure fed sewer reticulation system which drains raw sewage from the community to the WwTP (Figure 4). The Ramining WwTP utilises waste stabilisation pond technology

to achieve secondary level treatment of sewage effluent. Based on current circumstances, the raw sewage is almost entirely domestic in nature with no chemicals added during the treatment process. The WwTP was constructed in September 1981 (Power and Water 2021). The ponds consist of a primary facultative pond which gravity feeds into two secondary maturation ponds.

There is no gross pollutant screening, grit removal, maceration or storm flow separation located on the inlet to the pond system. The majority of the removal process for gross pollutants and other entrained materials is via sedimentation to sludge layers or entrapment in concentrated surface scums that can be physically removed. Desludging of the WSPs is conducted periodically to remove accumulated solids and increase hydraulic performance, which may result in improved treatment performance. Desludging was most recently completed in the primary pond in October 2014.

WDL wastewater monitoring commenced in July 2016, consistent with WDL 206. Samples of the tertiary pond outlet are currently collected on a monthly basis. Monitoring results are included in the *PWC Annual Monitoring Report – Remote Community Waste Discharge Licences*, a summary is provided in Appendix 4 (Table7).




Figure 4: Ramining wastewater collection and treatment configuration

3.2 Discharge Regime

Discharge from the facility occurs from a gravity fed discharge pipe located in the final maturation pond. The discharge outfall is approximately 56 m in length and is located offsite in adjacent bushland.

Discharge is continuous on an as-required basis (discharge is all year round) and occurs to land which creates a surface watercourse. During the Dry Season, a majority of the discharge is removed through

evaporation, evapotranspiration and percolation through the dense vegetation and sandy tenosol loams. During the Wet Season however, the discharge reaches a tributary of the Glyde River.

The estimated mean outflow from Raminging WwTP is **261.1 kL/day**.

Note that a flow meter was previously installed at the Raminging discharge point. Currently this data set contains inconsistencies, reducing confidence in the data statistics. Further data collation and assessment is required over a longer-term to provide more accurate measurements. Inflow data from flow meters is also not currently available, estimations have been utilised based on forecast sewage Equivalent Tenement (ET) flow, which may not accurately represent the inflow to outflow ratio on site.

3.3 Pond Performance

WSPs offer a low input, cost effective form of wastewater treatment that is particularly applicable in higher temperature environments with sufficient available land area. While the inputs are low, because it is largely driven by solar energy, the processes are no less complex and are largely controlled by the appropriate design and maintenance of the pond system to achieve the treatment performance required.

The ponds ultimately provide a centralised treatment barrier that prevents direct contamination of the receiving environment and have an important role in the protection of both environmental and public health.

Wastewater monitoring at the Raminging primary pond inlet commenced in August 2018. Over time, this data will provide an accurate characterisation of the raw effluent entering the waste stabilisation pond system, and an indication of treatment performance.

Pond treatment performance can be measured at remote community sites utilising mean biochemical oxygen demand (BOD) removal performance and mean predicted *E.coli* disinfection performance. The results are a reduction in concentration levels from the primary pond inlet to the final pond outlet.

The mean removal percentage at the Raminging WSPs has been calculated using data collected following the submission of the previous Environmental Risk Assessment and includes data from August 2022 to January 2025:

- Biochemical Oxygen Demand (BOD): **-188.5%**
- Free Ammonia (NH₃-N): **35%**
- Total Nitrogen (TN): **3.6%**
- Total Phosphorus (TP): **-37%**

The average log reduction for the pathogens indicator is:

- *E. coli*: **1.6 log reduction**

Further monitoring data, statistical analysis and investigation is required to verify these results.

For the scope of this risk assessment, wastewater quality monitoring data collected at the final pond discharge point to the receiving environment are illustrated on the conceptual site model (CSM) Appendix 1 (Figure 7), and water quality table Appendix 4 (Table 7).

3.4 Receiving Environment

The immediate receiving environment is a discharge influenced surface watercourse approximately 250 m long (Figure 5). It consists of a tall open eucalyptus forest dominated by Darwin woollybutt (*Eucalyptus miniata*) and stringybark (*Eucalyptus tetradonta*) with a grassy understorey.



Figure 5: Unnamed Creek (2011)



Figure 6: Raminging discharge point (PWC 2022)

The receiving water receptor is a tributary of the Glyde River which is located approximately 1.8 km south east from the discharge point. The tributary interconnects with the Arafura Swamp wetlands which is an important wetlands system. It is highly unlikely that any discharge reaches the Glyde River itself, being 5 km

away. It is unknown how frequently the discharge reaches the wetlands or whether the flow infiltrates and evaporates before reaching this area; further investigation is required.

The receiving environment is considered to have experienced minor disturbance (PWC 2010) due to the cultural uses of the area and presence of weeds species such as Mimosa (*Mimosa pigra*) and Olive Hymenachne (*Hymenachne amplexicaulis*).

Ramingining is located on the north western edge of the Arafura Swamp site of conservation significance number 20 (Appendix 2). The site is the most extensive melaleuca wetland in Australia and contains seven threatened species. The conservation status for these species listed under the Territory Parks and Wildlife Conservation Act 2000 (TPWC) and the Commonwealth Environment Protection and Biodiversity Conservation Act 1999 (EPBC) are summarised below in Table 1.

Table 1: Conservation status of species at risk from the area surrounding Ramingining WwTP.

Common name	Species name	National Status (EPBC)	NT Status (TPWC)
Plants			
Australian Arenga Palm	<i>Arenga australasica</i>	-	-
Climbing Pandan	<i>Freycinetia percostata</i>	-	VU
Vertebrates			
Australian Bustard	<i>Ardeotis australis</i>	-	-
Partridge Pigeon	<i>Geophaps smithii</i>	VU	VU
Northern Quoll	<i>Dasyurus hallucatus</i>	EN	CR
Merten's Water Monitor	<i>Varanus mertensi</i>	EN	VU
Yellow-spotted Monitor	<i>Varanus panoptes</i>	-	VU

CR – Critically Endangered, EN – Endangered, VU – Vulnerable, NT – Near Threatened, DD – Data Deficient

3.5 Screening Level Risk Assessment

A screening level risk assessment is used to determine if a risk to the assessment end-point exists that should be further investigated. It is a method for prioritising risks and minimising effort in assessing low risks. Table 3 provides a summary of the screening level risk assessment.

Risk hypotheses for the stressors identified in the conceptual site model (CSM) (Appendix 1, Figure 7) are defined with respect to their potential effects on the identified values of the receiving environment.

The identified values of the receiving environment are summarised below in Table 2.

Table 2: Identified values of receiving environment at risk from the Ramasing WwTP

Values	Receptors	
Cultural/ Human Health	Humans	Fishing Hunting Food gathering Visible water quality Sacred sites
Environment	Marine	Fish Freshwater turtles Macroinvertebrates
	Terrestrial	Waterbirds Invertebrates Mammals Reptiles
	Plants	Native vegetation Water plants

Table 3. Screening level risk assessment for key indicators and stressors associated with Ramininging WwTP discharge.

Indicator (water quality parameter)	Stressor (change to indicator)	Risk Hypothesis		Assessment end-points		Scope of this desktop ERA	Further investigation required?
		ENVIRONMENTAL	CULTURAL	ENVIRONMENTAL	CULTURAL		
Gross pollutants	Presence and accumulation of gross pollutants from influent carried through to effluent	That gross and micro-scale pollutants are ingested by biota resulting in death of animals and environmental degradation.	That gross pollutants are resulting in the reduction of visual amenity in the receiving environment.	To maintain the presence of biota in the environment.	To maintain the visual amenity of the environment.	The WwTP is considered a relatively effective barrier to gross pollutant entry to the receiving environment. This is due to the settling out to sludge layers and accumulation on pond surface where gross pollutants are physically removed as required. No evidence of gross pollutant accumulation during visual monitoring of discharge site (qualitative discharge criteria). No further investigation necessary at this stage.	No
Organic matter	Increase in BOD, decrease in DO	That BOD is leading to oxygen depletion in the environment resulting in loss of biota (e.g. fish kills) and changes to ecosystem structure.	That BOD is leading to odours resulting in the reduction of amenity in the receiving environment.	To maintain the presence of biota in the environment.	To maintain oxygen levels in the environment sufficient to prevent production of odours.	The median concentration of BOD in the discharge of Ramininging WwTP is 43.0 mg/L. As BOD is present in the discharge, it is determined at a screening level that a risk is present and further investigation is necessary.	Yes
Nutrients (nitrogen and phosphorus)	Increase in nutrient concentrations	That nutrients are leading to nuisance plant growth (e.g. phytoplankton blooms) resulting in oxygen depletion; displacement of endemic species; diminished light availability; release of toxins; and changes to ecosystem structure.	That nutrients are resulting in the reduction of amenity of receiving environment through reduction in water clarity, objectionable discolouration and odours; toxic blooms that are a public health risk; and blooms of toxin producing species whereby the toxins bio-accumulate in shellfish and fish ingested by humans.	To maintain nutrient levels so that the levels of primary production do not have an adverse impact on ecosystem structure.	To maintain the amenity of the environment.	As nutrients are present in the discharge, it is determined at a screening level that a risk is present and further investigation is necessary.	Yes
Toxicants	Increase in free ammonia concentration	That free ammonia is resulting in toxicity to aquatic organisms in water and sediments.		To maintain the presence of biota in the environment.		The median concentration of free ammonia in the discharge of Ramininging WwTP is 10.0 mg/L. At a screening level it is determined that a risk is present and further investigation is necessary.	Yes
Pathogens	Presence of <i>E. coli</i>		That pathogens are leading to the contamination of water resulting in primary and secondary contact recreation a public health risk; and accumulation in shellfish resulting in the consumption of shellfish a public health risk.		To maintain that pathogens from municipal wastewater are not increasing the risk of illness via primary and secondary contact recreation and consumption of shellfish.	The median pathogen concentration in the discharge of Ramininging WwTP is 980.0 MPN/100mL. At a screening level it is determined that a risk is present and further investigation is necessary.	Yes

4. Risk Analysis and characterisation

4.1 Power and Water Risk Management Framework

Power and Water has adopted a qualitative risk assessment methodology aligned to the Australia/New Zealand Standard “AS/NZ 4360: Risk Management”. This process is used to assess and manage activities that have potential to cause environmental harm.

The first step in the ERA process is to identify the aspects (problem formulation i.e. discharge of treated wastewater) (section 2.0) and corresponding potential impacts associated with each assessment endpoint identified in the screening level risk assessment as seen in Table 3.

This methodology is based on knowledge of the existing environment and incorporates site specific environmental factors into the analysis of the potential impacts. An assessment of each impact is analysed for likelihood and consequence.

The categories and associated rankings for environmental impact consequences are shown in Appendix 3 (Table 4). The likelihood of an event occurring and a risk score for each potential impact is determined by combining likelihood with consequence results as seen in Appendix 3 (Table 5).

Low to medium risks can typically be managed by routine procedures and integration into management plans, while high to extreme risks require senior management attention, immediate action or more detailed research and management planning.

3.1.1 Risk assessment for key indicators and stressors identified in screening level assessment.

Table 4: Risk assessment for key environmental and cultural assessment endpoints associated with Ramininging WwTP discharge using corporate risk ranking methodology

Hypothesis	Consequence		Likelihood	Inherent Risk Rating	
Environmental					
BOD is leading to oxygen depletion in the environment resulting in loss of biota and changes to ecosystem structure .	Based on the 2023-2024 monitoring data, Ramininging WwTP BOD discharge quality is 43.0 mg/L. Limited dilution of the treated wastewater would occur adjacent to the outfall in the dry season. The estimated dilution volume ratio between the effluent (261.1 kL) and the Arafura Swamp receiving environment in the wet season has been estimated at 1:30 (Appendix D: Dilution ratio for Ramininging WwTP and Arafura Swamp), suggesting any observed oxygen demand would be absorbed by this environment.	Moderate	Based on the dilution ratio between effluent and receiving environment, PWC considers that the likelihood of oxygen depletion in the receiving environment is unlikely as Ramininging WwTP discharges to ground and flow travels significant distance (2.2 km) to the Arafura Swamp.	Unlikely	Medium
Free ammonia is resulting in toxicity to aquatic organisms in water and sediments.	Based on the 2023-2024 monitoring data, Raminining WwTP free ammonia discharge quality is 10.0 mg/L. One of the most visible means by which toxicity presents in an aquatic ecosystem is through the occurrence of fish kills. No fish kills reported to date.	Moderate	Stressor not typically observed with such small discharge volumes to ground. Likelihood greater during Dry Season where there are flushing constraints. Based on the sampling results to date, PWC considers that the likelihood of toxicity to aquatic organisms is unlikely – during the Dry Season discharge flows considerable distance to the Arafura Swamp, during the Wet Season substantial dilution would occur.	Unlikely	Medium
Nutrients are leading to nuisance plant growth resulting in oxygen depletion; displacement of endemic species; diminished light availability; release of toxins; and changes to ecosystem structure.	Based on the 2023-2024 monitoring data, Ramininging WwTP contributes 8.2 and 0.3 tonnes/year of total nitrogen and phosphorus respectively. The discharge area is densely vegetated with tall eucalyptus suggesting transpiration and uptake of nutrients from the discharge. Movement through sandy loam (tenosols) (DLRM 2016) would also reduce nutrient load.	Moderate	Based on the sampling results to date, PWC considers that the likelihood of nuisance plant growth in the receiving environment is unlikely due to discharge to ground,	Unlikely	Medium
Cultural					
BOD is leading to odours resulting in the reduction of amenity in the receiving environment.	The swamp is identified as having cultural beneficial uses for primary and secondary recreation. Evidence of vehicle tracks indicates the swamp is readily accessed from a number of terrestrial points. Impacts are anticipated to be localised.	Moderate	Odours unlikely to be sustained during Wet Season due to the area being well flushed. Likelihood greater during Dry Season where there are flushing constraints. No evidence of odours during monitoring of discharge location at final pond (qualitative discharge criteria). PWC considers that the likelihood of reduction in amenity from BOD is unlikely.	Unlikely	Medium
Nutrients are resulting in the reduction of amenity of receiving environment through reduction in water clarity , objectionable discolouration and odours .	The swamp is identified as having cultural beneficial uses for primary and secondary recreation. Evidence of vehicle tracks indicates the swamp is readily accessed from a number of terrestrial points. Impacts are anticipated to be localised.	Moderate	Historical evidence indicates reduction in water clarity and objectionable green discolouration of receiving water during Dry Season. No odours noted during monitoring of discharge site however the immediate discharge area may have a reduction in amenity due to flow to ground through bushland (qualitative discharge criteria). PWC considers that the likelihood of reduction in amenity from nutrients is likely.	Likely	High
Nutrients are resulting in toxic blooms that are a public health risk; and blooms of toxin producing species whereby the toxins bio-accumulate in shellfish and fish ingested by humans.	The swamp is identified as having cultural beneficial uses for primary and secondary recreation including exposure through fishing and hunting. Filter feeding shellfish species unlikely to be present in receiving environment.	Moderate	Based on the primary and secondary contact recreation and cultural uses of the swamp, Power and Water considers that the likelihood of toxicant exposure is possible.	Possible	Medium
Pathogens are leading to the contamination of water resulting in a public health risk through primary and secondary contact recreation.	The swamp is identified as having cultural beneficial uses for primary and secondary recreation including fishing and hunting for food such as magpie geese eggs.	Moderate	Based on the primary and secondary contact recreation and cultural uses of the swamp, Power and Water considers that the likelihood of illness from pathogen exposure is possible during periods of high rainfall.	Possible	Medium
Pathogens are leading to accumulation in shellfish resulting in a public health risk through the consumption of shellfish.	Filter feeding shellfish species unlikely to be present in receiving environment.	Moderate	Based on the absence of shellfish species in the receiving environment, PWC considers that the likelihood of illness from pathogen exposure through the consumption of shellfish is rare.	Rare	Medium

5. Summary

The ERA found that the identified values of the Arafura Swamp (Glyde River) at risk from the Ramining WwTP discharge were environmental and cultural.

The key stressors that posed a risk to these values were the presence and accumulation of gross pollutants from influent carried through to effluent; increase in BOD; increase in nutrient concentrations; increase in free ammonia concentration and the presence of *E. coli*.

The ERA process has determined that the discharge from the Ramining WwTP poses a medium to high risk to the identified values of the receiving waterway. The influence of the discharge on the receiving environment is considered sustainable given the low discharge volumes and the removal of nutrients and pathogens through the dense vegetation at the outfall. Based on this ERA and water quality data, there is limited evidence to suggest deleterious impacts to the receiving environment.

All risk rankings have considerable uncertainties attached to the assessments. The risk rankings may change as uncertainties associated with current assessments are addressed.

Based on the ERA process and outcomes, PWC make the following recommendations:

- continue monitoring quality of wastewater discharged to the environment;
- incorporate recommendations into future Performance Improvements Plans;
- investigate options to accurately quantify the volume of treated wastewater discharged to the environment; and
- update the ERA and CSM based on new information and additional wastewater quality data.

References

BushTel. (2024). *Population of Galiwinku based on ABS 2021 Census SA1*. Northern Territory Government.

Victoria EPA. (2023). *Guidance for Environmental and Human Health Risk Assessment of Wastewater Discharges to Surface Waters*. Publication 1287, Water Sciences and Environmental Public Health Branch, Science Division.

Department of Territory Families, Housing and Communities (DTFHC). (2022). *Indigenous Community Engineering Guidelines*. Northern Territory Government, Darwin.

Louey-Gung, J. (2011). *Remote Operations Waste Stabilisation Pond Performance Evaluation Modelling*. (D2011/73466). Power and Water Corporation, Darwin.

Gilltrap, A & Nielsen, I. (2010). *Sludge Surveys For General De-Sludging Assessment*. (D2011/1071). Precise Environmental, Queensland.

Power and Water. (2021). *Sewage Treatment Summary*. (D2018/352304). Power and Water Corporation, Darwin.

Power and Water. (2024). *Enterprise Risk Management Standard – Risk Management Guidelines*. (CONTROL0013). Power and Water Corporation, Darwin.

Power and Water. (2010). *PWC Sewer Pond Discharge Assessment*. (D2010/49573). Power and Water Corporation, Darwin.

Power and Water. (2015c). *ET Table Northern Communities*. (D2015/490320). Power and Water Corporation, Darwin.

Appendices

Number	Title
Appendix 1	Ramingining Conceptual Site Model
Appendix 2	Map of Arafura Swamp Site of Conservation Significance
Appendix 3	Power and Water Risk Matrix
Appendix 4	Water quality and estimated dilution Ratio for Ramingining WwTP

Appendix 1 – Ramininging Conceptual Site Model




Figure 7: Conceptual site model for the Ramininging WwTP.

Appendix 2 – Map of Arafura Swamp Site of Conservation Significance




Figure 8: Arafura Swamp site of significance map (NRETAS, 2008).

Appendix 3 – Power and Water Risk Matrix

Table 5: Power and Water risk consequence table.

CONSEQUENCES

The consequence (impact or outcome) associated with a risk is assessed using the following criteria:

RISK CONSEQUENCE TABLE					
Category	Insignificant	Minor	Moderate	Major	Severe
Health and safety	Physical: A near miss incident without injury or illness. Psychosocial*: No treatment needed from a health professional. *Notes: Psychosocial harm relates to the factors in the design or management of work that increases the risk of work-related stress and can lead to psychological or physical harm.	Physical: An incident resulting in a minor injury or illness, and first-aid treatment applied. Psychosocial: Reduced ability to perform tasks, no professional treatment needed.	Physical: An incident resulting in an injury or illness requiring medical treatment*. Psychosocial: Reduced ability to perform tasks, likely needs ongoing support from a health professional. *Notes: Medical treatment relates to treatment by a medical professional at a medical facility. Treatment at a worksite by a paramedic is a first aid injury, unless they are transported to a medical facility.	Physical: A serious incident: - Requiring hospitalisation (24hrs); and/or - Resulting in long-term permanent disabling; or - Exceeding of chemical exposure with acute health impacts. Psychosocial: Serious psychological treatment needed, reduced ability to perform tasks.	Physical: A serious incident resulting in any one or more of the following: - One or more fatalities; - One or more persons seriously injured (includes long-term disabling effect); - Widespread hospitalisation of members of the public or Power and Water's workforce. Psychosocial: Inability to perform tasks, ongoing extensive psychological treatment.
Financial (Impact on EBITDA)	Loss less than \$500K.	Impact between \$500K and \$5M.	Impact between \$5m and \$25m.	Impact between \$25m and \$50m.	Impact greater than \$50m.
Legal/ regulation	- Individual breach of obligation, procedure or policy. - Civil action, fines and/or civil penalties (refer to Financial definition)	- Notification to regulator required. - Regulator/external auditor non-conformance or request for further explanation - Functional breach of obligation, procedure or policy. - Civil action, fines and/or civil penalties (refer to Financial definition)	- Regulator/ external auditor issues improvement notice, multiple non-conformances or provisional improvement notice. - Systemic breach of obligation, procedure or policy. - Civil action, fines and/or civil penalties (refer to Financial definition)	- Regulator issues notices, corrective action order and/or penalties - Order to stop work - Multiple provisional improvement notices, prohibition notice. - Civil action, fines and/or civil penalties (refer to Financial definition)	- Successful criminal prosecution imprisonment of Power and Water director and/or officer. - Royal Commission, parliamentary or other government inquiry, - Loss of licence to operate. - Civil action, fines and/or civil penalties (refer to Financial definition)
Environmental	Localised low level damage controlled but no remedial action required.	Localised low level damage controlled and remedied with minimal resources.	Widespread temporary damage with extended resources to remedy.	Long-term detrimental effect on environment and once controlled results in minor permanent damage.	Substantial permanent damage to widespread and sensitive areas.
Reputation	- No media attention; and/or - Isolated community or individual issue-based concern; and/or - Localised employees dissatisfaction which is managed by normal business processes;	- Occasional once-off negative media attention; and/or - Localised community impacts and customer concerns; and/or - Localised employees dissatisfaction which requires human resources in resolution;	- Brief adverse media attention and/or - Community/customer condemnation; and/or - Limited, localised loss of confidence by the community; and/or - Reduced confidence of key stakeholders - Localised employees dissatisfaction with localised impacts to service delivery	- Prolonged adverse media attention and/or - Community/ customer condemnation; and/or - Prolonged, widespread community/ customer loss of confidence; and/or - Confidence of key stakeholders damaged - Widespread dissatisfaction and loss of confidence by employees resulting in temporary service delivery	- Sustained adverse media attention and/or - Community/customer condemnation; and/or - Sustained community/ customer loss of confidence; and/or - Loss of stakeholder confidence in Board and/or - Management; and/or - Widespread dissatisfaction by employees resulting in sustained service delivery and industrial action
Customer (Impact due to disruption to services)	- No loss of supply. Issues rectified with corrective action. - Loss of water supply <= 2 hours in any urban or remote community	- An event resulting in loss of a single residential feeder for 15 to 30 minutes - Loss of water supply >2 hrs and <= 6 hours in any remote community - Loss of water supply in urban area, restored within expected timeframes (<=4 hours)	- An event resulting in loss of a single to multiple zone substations for up to 3 hours - Loss of water supply >6 and <=12 hours in any remote community - Loss of water supply in urban area outside of expected timeframes (> 4 hours and <=12 hours).	- An event resulting in loss of a single to multiple zone substations affecting CBD, town centres, commercial, and emergency services lasting up to 6 hours - Loss of water supply >12 hours < =24 hours in any urban area or remote community.	- An event resulting in loss of a single to multiple zone substations affecting CBD, town centres, commercial, and emergency services lasting > 6 hours - Complete loss of water supply (>24 hours) in any urban or remote community.

LIKELIHOOD

The likelihood of a risk occurring is assessed using the following scale:

(E) Almost certain	Event is expected to occur on a regular basis. One or more times per annum.	Not applicable
(D) Likely	An event is expected to occur from time to time. Once every 1 – 3 years	Probability of occurring is greater than 33%
(C) Possible	An event should occur at some time. Once every 4 – 10 years.	Probability of occurring is greater than 10% and up to and including 33%
(B) Unlikely	An event could occur at some time. Once every 11 to 30 years	Probability of occurring is greater than 3% and up to and including 10%
(A) Rare	An event not expected but possible. Less than once in 30 years	Probability of occurring is up to and including 3%

RISK RATING

Consequences and Likelihood

		Consequence				
		Insignificant (1)	Minor (2)	Moderate (3)	Major (4)	Severe (5)
Likelihood	Almost certain (E)	Medium	High	Very High	Extreme	Extreme
	Likely (D)	Low	Medium	High	Very High	Extreme
	Possible (C)	Low	Low	Medium	High	Very High
	Unlikely (B)	Low	Low	Medium	High	High
	Rare (A)	Low	Low	Low	Medium	Medium

ACTIONS AND REPORTING

	Low	Medium	High	Very High	Extreme
Escalation (new risk or reassessment)	Reported through risk review process.	Reported through risk review process.	Reported to executive general manager	Reported to CEO / Executive Leadership Team as soon as practicable.	Reported to Board Chair as soon as practicable.
Reporting to ARMC	Not applicable.	Not applicable.	To be reported to Audit and Risk Management Committee on a quarterly basis.	To be reported to Audit and Risk Management Committee on a quarterly basis.	Exception reporting as soon as practicable.
Tolerance	Tolerable unless otherwise determined by management.	Tolerable unless otherwise determined by management.	Tolerance to be determined by executive general manager.	Tolerance to be determined by CEO / Executive Leadership Team.	Tolerance to be determined by Board.
Risk monitoring	Reporting frequency to be annual.	Reporting frequency as per related business process.	Status to be reported to executive general manager at each business unit management meeting. Reporting frequency to be quarterly.	Status to be reported to each ELT. Reporting frequency to be quarterly	Status reported to each Board meeting. Reporting frequency to be quarterly

Note: "Escalation" refers to the escalation of **risks** (i.e. events that could happen in future) not **incidents** (events that have happened). Escalation of incidents is covered by the *HSE Incident and Investigation Management Procedure (CONTROL0070)*.

Figure 9: Power and Water likelihood, risk ranking, actions and reporting matrix.

Appendix 4 – Water quality and estimated dilution Ratio for Raminging WwTP and Arafura Swamp



Figure 10: Approximate catchment surrounding unnamed surface watercourse downstream of Raminging WwTP outfall (Google Earth, 2017).

Table 6: Discharge volume and dilution ratio estimate

Approx. area upstream of Arafura Swamp (m²)	Mean rainfall (Jan-Mar) (mm/d)	Mean evaporation (Jan-Mar) (mm/d)	Mean treated wastewater outflow (kL/d)
3,100,000	8.9	5.3	261.1
Volume of rainfall capture upstream of Arafura Swamp (rainfall-evap) (kL/d)	8,043		
Dilution ratio prior to entering ocean environment	1:30		

(Rainfall data source: Milingimbi Airport, BOM station number 014404)

Table 7: Summary of 2023-2024 Raminging water quality results

Sample Location/Asset: SRA090 (Pond 3 Outlet)	
Indicator	Median
Physio-chemical Parameters	
pH (pH units)	7.18
Electrical Conductivity (uS/cm)	310.0
Dissolved Oxygen (% Saturation)	59.0
Turbidity (NTU)	3.2
Total Suspended Solids (mg/L)	125
Biological Parameters	
Biochemical Oxygen Demand (mg/L)	43
Chlorophyll-a (ug/L)	1,042
Nutrient Parameters	
Ammonia (Total as N – NH3-N) (mg/L)	10
Total Nitrogen (mg/L)	27.3
Oxidised Nitrogen (NOx) (mg/L)	0.1
Total Phosphorus (mg/L)	3.2
Pathogen Indicators	
Escherichia coli Log10(E. coli/100mL)	2.99
Enterococci Log10(Enterococci/100mL)	4.49

Contact

Assurance
Water Services
Power and Water Corporation
WDLCorrespondence.PWC@powerwater.com.au
powerwater.com.au

