

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	10.39am Thursday 22 September 2016
Person / Company:	Power and Water Corporation
Incident:	Hydrocarbon leak – Umbakumba – Groote Eylandt

(a) the incident causing or threatening to cause pollution	Hydrocarbon leak
(b) the place where the incident occurred	Umbakumba – Groote Eylandt
(c) the date and time of the incident	2pm Monday 19 September 2016
(d) how the pollution has occurred, is occurring or may occur	Underground fuel line breakage due to unauthorised excavation and incorrect repair resulting in a diesel leak to ground
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	Upon notification of the incident, Power and Water has/will be undertaking the following actions: • All valves associated with fuel line have been closed • Professionally repairing and pressure testing line being undertaken • Remediation of the affected area
(f) the identity of the person notifying the NT EPA	PWC Environmental Services Team on behalf of Remote Operations