

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	11/01/18 16:00PM
Person / Company:	Power and Water Corporation
Incident:	Overflow of diluted treated effluent.

(a) the incident causing or threatening to cause pollution	Overflow of diluted treated effluent.
(b) the place where the incident occurred	Pine Creek Wastewater Ponds (Lot 149)
(c) the date and time of the incident	10/01/18 2:14AM Ongoing at time of reporting.
(d) how the pollution has occurred, is occurring or may occur	Due to high rainfall the effluent volume within the wastewater ponds is beyond capacity resulting in an offsite discharge.
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	Prevent/Rectify: Incident rectification based on reduction in catchment rainfall levels. Overflow will cease when volumes in the system reduce. Control: Crews monitoring site to manage overflow pathway. Clean-up: Overflow is treated effluent, sewage debris is not present.
(f) the identity of the person notifying the NT EPA	PWC Environmental Services Team on behalf of Water Services.