

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	20-3-20 1:00pm
Person / Company:	James Taylor Puma Energy
Incident:	Septic Overflow

(a) the incident causing or threatening to cause pollution	Over Flow From Septic – non solids
(b) the place where the incident occurred	Berrimah Puma Energy
(c) the date and time of the incident	19-3-20 10:00am
(d) how the pollution has occurred, is occurring or may occur	Pump had tripped out causing the tank to fill and over flow.
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	Pump has been reset and the tank has pumped down to correct levels. Diagnosing of the potential cause/causes and we are working to rectify the issue to prevent future issues.
(f) the identity of the person notifying the NT EPA	Unknown