

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	Incident was notified to the Pollution Hotline at 1.42 pm 22/08/22.
Person / Company:	City of Darwin (EPL 188-03)
Incident:	Benevap concentrate tank overflow
(a) the incident causing or threatening to cause pollution	Leachate concentrate spill of approximately 200 L 
(b) the place where the incident occurred	Northern leachate pond (leachate evaporation zone), Shoal Bay Waste Management Facility
(c) the date and time of the incident	The spill was discovered during Veolia's morning inspection on Monday the 22/8/2022 at 8:55am

(d) how the pollution has occurred, is occurring or may occur	The pump that transports the concentrate leachate from the overflow tank to the leachate holding area malfunctioned, leading to leachate spill. 
(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	Spill was contained immediately and banded using soil. The spill has not reached the surrounding drainage. 
(f) the identity of the person notifying the NT EPA	Shane Coleman/City of Darwin. Incident was notified to the Pollution Hotline at 1.42 pm 22/08/22.