

SECTION 14 INCIDENT REPORT (*Waste Management and Pollution Control Act*)

Date and Time of Notification:	Approx 1.35 pm 3/11/22 – Verbal (Patrick Oldfield, Depot Manager – Refuel Australia) Online form 12.45 am 4/11/22
Person / Company:	Ian Burrows – Managing Director Kathryn Wade – HSE Manager
Incident:	Diesel tank overflow – Ampol Truck Stop, Smith Street, Ciccone, Alice Springs, NT
(a) the incident causing or threatening to cause pollution	Tank overflow onto forecourt and drain approximately 1,389 litres diesel
(b) the place where the incident occurred	Ampol Truck Stop, Smith St, Ciccone, Alice Springs, NT
(c) the date and time of the incident	03/11/2022 – 11.00 am
(d) how the pollution has occurred, is occurring or may occur	Diesel overflowed from underground tank on to concrete and bitumen driveway. Small amount entered two drains. Diesel and water removed from drain.

(e) the attempts made to prevent, reduce, control, rectify or clean up the pollution or resultant environmental harm caused or threatening to be caused by the incident	• Shut site down as soon as incident identified • Contacted Emergency Services including Police & Fire Brigade • Contained product in area • Used spill kits to contain product • Had sand placed over all product • Pumped out product (and additional water) from drain and now stored in IBC's in Ampol Depot, Ghan Road, Ciccone, Alice Springs, NT • Ordered skip bins with plastic lining to store contaminated sands – sand contained in skip bins. • Covered edges of site with additional sand.
(f) the identity of the person notifying the NT EPA	Ian Burrows - Managing Director Revision 3 completed by Kathryn Wade – HSE Manager, 8/11/2022